



**ADDENDUM NO. 02
December 12, 2024**

To Proposal Bid Package

**DISTRICT-WIDE ACCESS CONTROL UPGRADES
PACKAGE 4
CLOVIS UNIFIED SCHOOL DISTRICT**

Notice to Bidders:

- A. Receipt of this Addendum shall be acknowledged on the Bid Form.
- B. This Addendum forms part of the Contract documents for the above referenced project and shall be incorporated integrally therewith.
- C. Each bidder shall make necessary adjustments and submit his proposal with full knowledge of all modifications, clarifications, and supplemental data included therein. Where provisions of the following supplemental data differ from those of the original Contract Documents, this Addendum shall govern.

GENERAL

Item No 01 Drawing Updates

1. Sheet 4-CIS-AC2 – Clark Intermediate – Administration Building
 - A. For door DR01, the auto operator should be listed as #9542 HDR2 in lieu of #9542 HDR
2. Sheet 4-CIS-AC7 – Clark Intermediate – MPR Building
 - A. New access control panel shall be installed in staff lounge located near where keyed note #6 (existing electrical panel) is located. Install access control panel in the same room as the existing electrical panel.

Item No 02 General Item

1. Door hardware contractor shall provide end cap modules for any armored door loops.

End of Addendum 02